

四川省电力公司2024年四季度供电可靠性

单位	全口径2024年全口径供电可靠率(%)	2024年城网供电可靠率(%)	2024年农网供电可靠率(%)
四川省	99.866	99.957	99.852
成都	99.940	99.981	99.927
达州	99.871	99.944	99.863
南充	99.869	99.952	99.857
内江	99.828	99.960	99.808
宜宾	99.872	99.946	99.853
自贡	99.872	99.954	99.846
天府新区	99.916	99.953	99.915
泸州	99.862	99.937	99.853
攀枝花	99.897	99.960	99.880
凉山	99.805	/	99.805
绵阳	99.868	99.930	99.856
乐山	99.830	99.938	99.818
德阳	99.859	99.944	99.846
广元	99.855	99.944	99.848
巴中	99.873	99.970	99.865
广安	99.864	99.968	99.854
眉山	99.872	99.958	99.867
资阳	99.837	99.922	99.822
阿坝	99.717	/	99.717
遂宁	99.892	/	99.892
雅安	99.766	99.941	99.749
甘孜	99.697	/	99.697

四川省电力公司2024年四季度电压合格率

单位	综合(%)	城网(%)	农网(%)
四川省	99.878	99.905	99.853
德阳	99.876	99.891	99.864
凉山	99.834	99.832	99.838
雅安	99.848	99.873	99.837
绵阳	99.895	99.911	99.867
天府新区	99.878	99.888	99.824
乐山	99.875	99.892	99.871
眉山	99.919	99.93	99.911
成都	99.918	99.937	99.859
资阳	99.883	99.907	99.863
巴中	99.892	99.927	99.885
自贡	99.873	99.921	99.852
达州	99.873	99.878	99.869

阿坝	99.793	99.828	99.75
泸州	99.856	99.888	99.843
南充	99.866	99.912	99.837
宜宾	99.869	99.877	99.856
甘孜	99.771	99.866	99.74
广安	99.87	99.885	99.855
攀枝花	99.919	99.91	99.913
遂宁	99.892	99.905	99.872
内江	99.89	99.915	99.88
广元	99.876	99.903	99.864
岷江	99.711	99.872	99.275